

## Specifications

### Solid Plastic Partitions

### Ceiling Hung

### 4.9

#### Solid Plastic Partitions with Ceiling Hung Mount Style

##### Part 1 - General

###### 1.01 Work Included

A. The toilet partitions shall be high-density polyethylene (HDPE) polymer with ceiling hung mounting style as manufactured by **ASI Accurate Partitions**, Burr Ridge, Illinois.

B. Furnish all labor and materials necessary for completion of work in this section as shown in the approved drawings and specified herein.

**Related Work** – Specified elsewhere shall include accessories and anchorage/blocking for attachment of partitions.

##### Part 2 Product

**2.01 Door, Panels, Pilaster and Urinal Screens** – Shall be 1" thick (door and panels 55" high, pilasters 84" max. length for 96" maximum finished ceiling height) HDPE polymer that is water resistant and non-absorbent. A heat sink shall be attached as standard to the bottom of all doors and panels.

**2.02 Material** – The HDPE material shall have homogenous color throughout each component with ¼" machined edges for uniformity. Self-lubricating surface shall resist markings from pens, pencils and other writing instruments.

**2.03 Color**- Will be selected from **Accurate's** full range of standard designer colors.

**2.04 Door Hardware** – Hinges shall be 8" and fabricated from heavy-duty extruded aluminum alloy with a brushed anodized finish. Wrap-around flanges are mounted and thru-bolted to doors and pilasters with stainless steel tamper resistant barrel nuts and shoulder screws. Hinges operate on field adjustable, gravity activated cams that can be set in 30-degree increments. Emergency access is accomplished by lifting the door from the bottom.

Door Strike and Keeper: Shall be 6" and fabricated from heavy-duty extruded aluminum alloy with brushed finish.

Latch: Anodized extruded aluminum, with housing, slide bolt and button. Latch at accessible compartments shall be sliding type only.

**2.05 Mounting Hardware** – Brackets shall be extruded aluminum stirrup brackets. Brackets shall be thru-bolted to the panels with tamper resistant barrel nuts and shoulder screws.

**2.06 Construction Design**- Partitions shall be ceiling hung with 3/8" x 1" mounting bar attached to the top of the pilaster. Each mounting bar shall be secured to the overhead structural member with two 3/8" zinc plated bolts. Additional 4" wide horizontal cross bracing shall be secured at 82" above finished floor, cross bracing shall be attached to all pilasters and stay consistent in color to other material. The ceiling anchoring system shall be concealed by a type 304 stainless steel trim shoe with a #4 finish.

##### Part 3 – Execution

**3.01 Installation** – Shall be installed in accordance to the **ASI Accurate** installation instructions with partitions rigid, straight and plumb. Doors and panels shall be mounted 14" above the finished floor.

**3.02 Warranty** – **ASI Accurate Partitions** guarantees its solid plastic HDPE material against breakage, corrosion, and delamination for 25 YEARS from the date of receipt by the customer. If material is found defective during that period, the material shall be replaced free of charge. No credits or allowances shall be issued for any labor or expenses relating to the replacement of components covered under the warranty plan.